NET_MAX
17.9
NET
18.4/45.5
K_NET1
K_NET2
T01A_110
18.4/45.5
T01B_110
T02A_110
18.4/45.5
T02B_110
K_T1_T01
T1_01_HV
16.6/39.8
T_T1_01
T80/1
43.3/111.0
K_T1_T80
K_T80T40
T2_02_HV
17.9/43.7
T_T2_02
T80/12
32.5/85.6
K_T2_T80
K_T80A12
T80_SS1A
43.2/110.5
T80_SS2A
32.4/85.1
T80_SS1B
T80_SS2B
ST
K_COND
K_MAC_A
K_BAC_A
K_CHT801
K_CHT802
T80/4
35.5/79.5
T80/3
33.9/72.0
T80/6
42.9/109.5
T80/13
32.3/84.4
MAC_A
BAC_A
CH5
T80/5
42.6/107.6
T81/1
28.2/73.2
T81/9
22.1/58.5
K_CHT81A
K_CHT81B
K_T81AB
T81_A
26.1/65.1
T81_B
20.5/52.2
K_T81A1A
K_GAN2A
K_GAN1A
T81/2
25.1/59.0
T81/3
24.0/53.8
T81/4
24.1/54.2
GAN_2A
GAN_1A
T_T1_81A
T1_81ALV
55.1/135.5
K_T1_81A
K_T81T45
T2_01_HV
T1_02_HV
T3_02_HV
T2_01_LV
T1_02_LV
T3_02_LV
T70_A
T70_B
T40_SS1A
T40_SS2A
T40_SS1B
T40_SS2B
CH11
CH13
CH31
CH12
CH14
CH12
T46_A
T46_B
T46_C

Three phase short-circuit
acc. to IEC 909

Ik" [kA]
Name
short-circuit node
NAME
Ik" [kA]/ip [kA]
Ik" [kA]
Name

			US Steel Kosice 110-/6-kV-Network
	Date	Name	
Drawn	13.10.05	Hohenst.	max. 3ph. short-circuit normal operation
Check.			
Norm			
AREVA Network Planning Business			Figure 2
Original:		Repl. for:	Repl. by: