

Minutes of the Complaint Proceeding

Project: ASU No. 9 – U. S. Steel
SO 002 Compressor Building

Participants: HS HSV s.r.o. (the Supplier) – Mr. Fejko, Mr. Micák, Mr. Horváth
AIR LIQUIDE AGS GmbH (the Purchaser) – Mr. Martens

Description of the subject of the complaint:

The Purchaser submitted a complaint about the failure of 3 pc of ventilators – damaged ventilation blades.

Opinion and statement of the participants:

The Supplier HS HSV s.r.o. has replaced 3 pc of damaged ventilators, and has performed works on electrical installation in accordance with the drawings approved by the Purchaser in excess of the project documentation.

The above mentioned equipment has been tested and it has not shown any defects during the tests.

The Purchaser accepts herewith the above mentioned equipment into permanent operation and considers the subject of the complained failure to be removed.

Documents handed-over to the Purchaser:

- As-built project drawings of the electrical equipment
- Inspection and test report of the electrical equipment
- Certificates of the built-in materials

Košice, 05.12.2006

AIR LIQUIDE AGS GmbH
U.S. Steel, Košice vstupný areál
Site Manager ASU No. 9
SK 04014 Košice