

**TEST CERTIFICATE
ABNAHMEPRÜFERZEUGNIS
FICHE DE CONTROLE**

EN10204-2.2

CUSTOMER: Air Liquide AGS GmbH
Fütungsweg 34
D-447805
Krefeld
Germany

Serial nr. : 7769
Module B : 9001014
Module D1 : STW 302030636
Your order nr. : 4500023372
Our order nr. : R2-040241


DESCRIPTION: 1-off Gas Fired WWB vaporiser
DRAWING NR(S): CN 4185-1 rev. D, CN 4193-1 rev. E
TEST PRESSURE: 23 Bar
MAX. WORKING PRESSURE: 16 Bar
TAG NR. PRESS. INDICATOR: 5057
TEST MEDIUM: Water

CRYONORM B.V. HEREWITH CERTIFIES THAT THE ABOVE MENTIONED VAPORISER(S) IS/ARE SUPPLIED IN ACCORDANCE WITH THE SPECIFICATIONS AND ORDER REQUIREMENTS AND HAS/HAVE BEEN TESTED ON LEAKAGE AND FOUND TIGHT.

WE HEREWITH DECLARE THAT THE BELOW MENTIONED MATERIALS HAVE BEEN USED AND, THE PARTS ≤DN 50, HAVE NOT BEEN REMARKED.


MATERIAL CERTIFICATE NUMBERS:

According to Bill of materials

 **STOOMWEZEN**
Afd. Holland
Witnessed ☒ Reviewed ☐ Examined
01.12.2004

Alphen aan den Rijn: 01-12-2004

Quality control:


Quality Control
C.H.M. Elstgeest